

Council of the City of York, PA
Session 2013
Bill No.
Ordinance No.

INTRODUCED BY: **Michael Ray Helfrich**

DATE:

AN ORDINANCE

Amending Article 1501.04 "Changes in Fire Prevention Code" of the York City Codified Ordinances to establishing an Opt-in/Opt-Out provision for connection to the city's gamewell system.

BE IT ORDAINED, and it is hereby ordained by the authority of the same as follows:

SECTION ONE: That Article 1501.04 Changes in Fire Prevention Code" of the York City Codified Ordinances be amended as follows:

(15) Section 907.3.2.3. Transmission of Fire Alarm Signals is hereby added to read as follows: All required fire alarm systems shall transmit alarm signals by connection to the Municipal Alarm System of the City of York.

Exception #1: Where connection to the Municipal Alarm System of the City of York is not available, the fire alarm system shall be connected to a central station approved by the Chief of the Department of Fire/Rescue Services.

Exception #2: Smoke detectors in occupancies Use Group I-3 (see Section 907.14).

Exception #3: Smoke detectors in patient sleeping rooms in occupancies in Use Group I-2 (see Section 407.6.).

Exception #4: Group R-1 and R-2 occupancies provided with an approved automatic sprinkler system in accordance with 903.3, monitored by an approved central station monitoring company in accordance with 907.14 and containing less than five guest sleeping rooms.

Exception #5: Commercial facilities may be deemed exempt upon installation of redundant fire alarm systems with approval of the City Fire Department. The fire alarm system shall be connected to a central station approved by the Chief of the Department of Fire/Rescue Services.

PASSED FINALLY:

BY THE FOLLOWING VOTE:

YEAS: _____, _____, _____, _____, _____

NAYS: _____.

Carol Hill-Evans, President of Council

ATTEST:

Dianna L. Thompson-Mitchell, City Clerk

Presented to the Mayor for approval this _____ day of _____.

Approved: _____
Mayor

Date

Vetoed: _____
Mayor

Date